

# **D-Wire Sensors**

## Overview

### D-Wire Sensor Network (D-PK-DSNSR-12XXX)

D-Wire sensors are a way to track environmentals in your server room, telecom shelter, PBX closet, or data center using convenient daisy-chained sensors. With D-Wire sensors, you don't have to worry about analog capacity on your RTUs, tangled masses of sensors at your RTU, or even the trouble of wiring analog connectors.

D-Wire sensors from DPS use simple RJ-11 connectors, in and out, and allow you to chain up to 16 sensors to a single DPS RTU's D-Wire port. Your sensor chain can be a maximum of 600 feet, so you can run sensors out as far as you need to monitor your equipment, without having to place analog-capable RTUs in multiple places.

D-Wire Sensors available include:

- Temperature
- Temperature/Humidity
- · 3-Discrete Alarm Node
- External Temperature Node
- Analog Node for Voltages
- · Analog Node for 4-20mA Sensors



<b>Max/Min For Common D-Wire Sensors</b>							
	Min	Max	Accuracy	Resolution	<b>Operating Temp</b>		
Temp Sensor	-40°F	180°F	±0.5°F	0.05°F	-40°F	180°F	
Humidity Sen- sor	0% RH	100% RH	±3.5% RH	0.2% RH	32°F	122°F	
Analog Sensor	0V	12V	±2%	12 mV	-4°F	158°F	
Analog Sensor	0V	60V	±2%	60 mV	-4°F	158°F	

## **Key Benefits**

- D-Wire sensors do not need a power source.
- "Plug 'n' Play" functionality.
- The analog signal is digitized at the sensor, so the cable is less susceptible to noise and can be longer.
- Analog value is sent to the RTU for data logging and real-time reading.
- DPS Telecom D-Wire Sensors are more economical compared to 3rd-party alternatives.
- Sensors are uniquely identified by the host or RTU, allowing them to be supervised. This means if a sensor is unplugged or the cable is broken, the RTU can detect this and notify you.

# Call 1-800-622-3314 For Pricing

Visit our website at www.dpstele.com

4955 East Yale Avenue, Fresno, California 93727 • 800-622-3314 • Fax 559-454-1688

## **Hardware Installation**

### If connecting directly to a D-Wire enabled RTU:

Use standard CAT5E, straight-through RJ-11 or RJ-12 cable. Connect "In" jack on the temp sensor to the D-Wire or Digital Sensor input on your RTU.

#### If connecting to an existing chain of sensors:

Connect the "In" jack on the temp sensor to the "Out" jack on the previous sensor in the chain.





Fig 2 Pinout for D-Wire/TempDefender sensor ports

Fig 1 Connecting a chain of sensors to the D-Wire port on a RTU

## **Software Configuration**

1. Connect to the Web Interface for your DPS Telecom RTU

- Enter the IP address of your RTU in the address bar of your web browser
- Enter your user-name (if required) and password. The Default user-name is admin and password is dpstelecom.

2. Navigate to the **Sensors** option in Web Interface's Edit Menu.

3. Sensors connected to the NetGuardian will appear in the order connected. Your RTU will automatically recognize the sensor's type (temp, humidity, air flow, etc.) and populate the sensor ID and Unit fields. When you connect a sensor, the sensor's ID number (labeled on the side of the sensor) will appear in the first available Sensor ID field with a yellow background.

	Sensor ID		Rev	Notifications	
1	22a073270000001c	a073270000001c Temperature Detail:			
	Record freq: 15r	n Cor Coc			Thresholds: MjU: 32
	DeadBand: 1				MnU: 42 MnO: 85 MjO: 100
2	DeadBand: 1	Interior Humidity	Details>>	-	MnU: 42 MnO: 85 MjO: 100
23		interior Humidity	Details>> Details>>		MnU: 42 MnO: 85

4. Fill in any fields as necessary for your configuration

(i.e. thresholds, notifications, etc.). See the table on the following page for information about available fields in the Sensors section of the web interface.

#### 5. Click Save

Your sensors are now configured.

This Monitor section provides the measurements of each sensor. The **Monitor** >> **Sensors** screen provides a description of each sensor, the current reading, the units being read, and the alarm conditions (major under, minor under, major over, minor over) according to your software configuration.

The analog thresholds can be configured in the Edit >> Sensors menu as seen in Fig. 3.

Aonitor Menus: Alarms	Sen	sors		
Controls	Ba	50		
ensors				<b>L</b> .
ing Targets 🛛 🖞	1	Internal Temperature	84.5 F	None
lit Menus:	2	Humidity	65%	MnO
ystem	з	-Disabled-	0.0 F	None
thernet				
erial Port	4	-Disabled-	0.0 F	None

Fig 4 Properly configured sensors reporting values via the Sensors section in the Monitor Menu of the Web Interface

**Warning:** Using the incorrect cable or cable pinout can cause damage to your unit. The cable should always be a straight-through connection. To guarantee that the correct cable is used, call DPS Telecom for ordering options.

### For Service and Support, visit www.dpstele.com/support or call 559-454-1600